

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Moulded Case Circuit Breaker

Name and address of the applicant

Zhejiang Benyi New Energy Co., Ltd.
Wenzhou Bridge Industrial Zone, Beibaixiang Yueqing,
Zhejiang
P.R. China

Name and address of the manufacturer

Zhejiang Benyi New Energy Co., Ltd.
Wenzhou Bridge Industrial Zone, Beibaixiang Yueqing,
Zhejiang
P.R. China

Name and address of the factory

Note: When more than one factory, please report on page 2

Zhejiang Benyi New Energy Co., Ltd.
Wenzhou Bridge Industrial Zone, Beibaixiang Yueqing,
Zhejiang
P.R. China

Ratings and principal characteristics

Ui:500V; Uimp:8kV; Cat.A; Reference temperature:+40°C
Ue:DC500V; In:65/80/100/125A; Ics:15kA; Icu:15kA;
2P Appearance; Instantaneous tripping curve: Ii=10In

Trademark / Brand (if any)

ZJBENY

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

This Certificate is Amendment No.1 to CBTR ref. No.HU-004176, dated 2022-12-03, and is issued due to changing the name of Applicant/Manufacturer/Factory.

A sample of the product was tested and found to be in conformity with

IEC 60947-2:2016+A1

As shown in the Test Report Ref. No. which forms part of this Certificate

CN22B05J 002

This CB Test Certificate is issued by the National Certification Body